

Letter No. 40/SFS/03/05/22

Date:- 03.05.2022

Fire station Officer, Rajgir

To,

The Principal,

Tirthankar Mahaveer Vidya Mandir

Veerayatan, Pawapuri (Nalanda)

Sub:- Inspection Report regarding fire precautionary/ measures in your school.

Sir,

In view of your letter dated 07/01/2022 I inspected your school premises, Pawapuri on dated 23/04/2022


During inspection I found that the school is of 4 hrs fire resistance capacity and following active and passive fire protection arrangements:

1. School has two stair cases.
2. Corridors have enough width.
3. Every floor protected by fire extinguishers.


Suggestion

- All firefighting equipment should by maintain every time and a mock drill should also be done once in three months.


Your sincerely,
अग्निशमालय पदाधिकारी
राजगीर
Fire Station Officer,
Bihar Sharif


Principal
Tirthankar Mahaveer Vidya Mandir
Pawapuri (Nalanda)




Anjani Kumar
Manager
Veerayatan, Rajgir (NLD.)

FIRE SAFETY CERTIFICATE

NO. 2022-23/F3/40

Dated: 03.05.2022

Certified that the T. M. Vidya Mandir , Pawapuri..... (name of the building or premises) at Pawapuri, Nalanda(Bihar) comprised of01..... basement(s) and02.....(upper floors) owned/occupied by T. M. Vidya. Mandir , Pawapuri(name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of state/UT Fire Service Rules, and verified by the officers concerned of fire service on 23/04/2022. (date of inspection) in the presence of Mr.Uday kumar and Mr. Bipin Kumar (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy class Group B with effect from ...03/05/2022 For a period of ...01.....years in accordance with rule and subject to compliance of the conditions.

Issued on 03/05/2022 By

- Strike out whichever is not applicable.

Signature with Seal

Name :

Designation:

Madan Kumar
Fire Station Officer

अग्निशमालय पदाधिकारी
राजगीर

To

The PrincipalTrithankar MahaveerVidya Mandir, Pawapuri

(Name and address of the Institution)

ENDORSMENT

The No Objection Certificate issued Fire Service stand cancelled and annulled due to

.....(reasons to be recorded).

1 Kanchan Kishor
Principal
Tirthankar Mahaveer Vidya Mandir
Pawapuri (Nalanda)



Anjani Kumar
Manager
Veerayatan, Rajgir (NLD.)

INDIAN MARKETING SERVICE

REG/O: - NAZMA MANZIL KAZMI BEGUM COLONY PATNA- 800008

H/O :- BADI PAHARI PATNA GAYA MORE NEAR ADITIYA VISION PATNA- 800007

B/O :- MUMTAZ VILLA HOUSE NO-36 PARK CIRCUS AVENUE KOLKATA-700017

MOB :- 9934016078, 9546144786

E-MAIL:- indianmarketingservice@gmail.com

Web :- www.indianmarketingservice.com



CERTIFICATE



TO,
TIRTHANKAR MAHAVEER VIDYA MANDIR
PAWAPURI, NALANDA BIHAR
UNIT OF VEERAYATAN

Valid From: - 24-05-2022 to 23-05-2027

NEW SUPPLY OF FIRE EXTINGUISHER

S.NO	DESCRIPTION	QTY	IS NO
1	A.B.C POWDER TYPE FIRE EXTINGUISHER 6KG COMPLETE	12	15683
2	CO2 GAS TYPE FIRE EXTINGUISHER 4.5KG COMPLETE	12	15683

WE ALSO CERTIFY THAT THE ABOVE EXTINGUISHER ARE HYDRAULICALLY TESTED 100% AT 35 BAR FOUND SATISFACTORY & THAT ONE ON. OF FIRE EXTINGUISHER WAS RANDOMLY TESTED FOR PERFORMANCE & FOUND SARTISFACTORY AS PER IS.

Kanishk Kumar
Principal
Tirthankar Mahaveer Vidya Mandir
Pawapuri (Nalanda)



ISSUED BY FOR INDIAN MARKETING SERVICE.



Anjani Kumar
Anjani Kumar
Manager
Veerayatan, Rajgir (NLD.)

DEALS IN : ALL FIRE SAFETY EQUIPMENTS/ SAFETY DEVICES